

**MATTABASSETT DISTRICT
ADDENDUM RECEIPT CONFIRMATION SHEET**

DATE: MAY 26, 2022

PAGES: 03

PROJECT NAME: PRIMARY SEDIMENTATION BASIN NO.1 – SCUM SKIMMER SYSTEM
UPGRADE PROJECT

SUBJECT: **ADDENDUM NO. 2**

****REQUIRED****

TO CONFIRM RECEIPT OF THIS ADDENDUM PLEASE SIGN THIS CONFIRMATION SHEET
AND FAX TO (860)635-7290, OR EMAIL TO Kbober@mattdist.org, and ebrousseau@mattdist.org

THANK YOU

NAME _____

TITLE _____

SIGNATURE _____

COMPANY _____

ADDENDUM NO. 2
TO
BIDDING AND CONTRACT
REQUIREMENTS AND SPECIFICATIONS
FOR THE
THE MATTABASSETT DISTRICT, CROMWELL, CONNECTICUT
PRIMARY SEDIMENTATION BASIN NO.1 – SCUM SKIMMER SYSTEM UPGRADE
PROJECT – BID# 2022-26
WP PROJECT NO. 20950B

05/26/2022



PREPARED BY:
WRIGHT-PIERCE
169 MAIN STREET
700 PLAZA MIDDLESEX
MIDDLETOWN, CT 06457
PHONE: 860.343.8297 | FAX: 860.343.9504

**THE MATTABASSETT DISTRICT, CROMWELL, CONNECTICUT
PRIMARY SEDIMENTATION BASIN NO.1 – SCUM SKIMMER SYSTEM UPGRADE
PROJECT – BID# 2022-26**

ADDENDUM NO. 2

WP PROJECT NO. 20950B

As a point of clarification, the Contract Documents govern all aspects of the project. Discussions held during the Pre-Bid Conference or over phone or email are informal and informational only.

All official changes to the Contract Documents are made only by addenda. The following changes and additional information are hereby made a part of the Contract Documents:

A. QUESTIONS AND ANSWERS

Questions from the Contractors received are as follows:

NICKERSON GENERAL CONTRACTOR MAY 24th, 2022

1. *Q: Please confirm there are no AIS (American Iron and Steel) requirements for this project?*
A: The American Iron and Steel procurement requirement is not applicable for this project.

2. *Please answer the following questions regarding Section 09900 –*
 - a. *Electrical Conduit is listed under the painting schedule. The majority of the conduit required on this project is PVC coated or PVC. Please clarify if all the conduits should be painted.*
A: As indicated in Addendum No.1 - Painting of electrical conduits is not required.

 - b. *The painting schedules detail a number of different surfaces and materials to be painted/coated. Please clarify what needs to be painted / coated on this project?*
A: Painting is not anticipated for this project. However, if paint on existing surfaces is damaged by contractor as a result of work from this project, contractor shall use this Section as a guide to refinish damaged areas.

END OF ADDENDUM NO. 2